

## Revised Conditions

57. Roof drain runoff shall be mitigated using methods outlined in the 2022 City of Lacey Stormwater Design Manual (SDM) to satisfy criteria of Core Requirement #5 – On-Site Stormwater Management. (SDM 2.2.5).

77. In addition to the previously mentioned frontage improvements, overhead communications and utility lines shall be relocated underground by the developer and/or utility owner if the cumulative length of the parcel's frontage is over 500 lineal feet. High voltage transmission lines cannot be relocated underground. Where high voltage and distribution power lines exist, relocation above ground will be coordinated with the City of Lacey.