



ADDENDUM NO. 1
TO THE PLANS, SPECIFICATIONS, PROPOSAL AND CONTRACT
FOR CITY OF LACEY
JACOB SMITH HOUSE ROOF
LACEY CONTRACT NO. PW 2025-15

This addendum is made part of these contract documents as though it was originally included in the Contract. The Contractor shall note the location of the Addenda Receipt Acknowledgement on Page B-4 of the Contract Proposal.

Issued this 9th day of September, 2025.

Specifications

ITEM NO. 1-1: EDIT SECTION D 8-51.2 MATERIALS

Replace the treatment requirements in the Special Provisions Section D 8-51.2(1) with the following:

Treatment: Preservative-treated per AWP Standard U1. Class B fire-retardant treatment per IBC 1505.6.

Scott Egger, P.E.
Public Works Director